



Article Data-Driven Maintenance Priority and Resilience Evaluation of Performance Loss in a Main Coolant System

Hongyan Dui ¹, Zhe Xu ¹, Liwei Chen ^{2,*}, Liudong Xing ³ and Bin Liu ⁴

- ¹ School of Management Engineering, Zhengzhou University, Zhengzhou 450001, China; duihongyan@zzu.edu.cn (H.D.); 202022302015128@gs.zzu.edu.cn (Z.X.)
- ² School of Electrical Engineering, Zhengzhou University, Zhengzhou 450001, China
- ³ Department of Electrical & Computer Engineering, University of Massachusetts, Dartmouth, MA 02747, USA; liudong.xing@umassd.edu
- ⁴ Department of Management Science, University of Strathclyde, Glasgow G1 1XQ, UK; b.liu@strath.ac.uk
- * Correspondence: cliwei@zzu.edu.cn; Tel: +86-371-67781582

Abstract: The main coolant system (MCS) plays a vital role in the stability and reliability of a nuclear power plant. However, human errors and natural disasters may cause some reactor coolant system components to fail, resulting in severe consequences such as nuclear leakage. Therefore, it is crucial to perform a resilience analysis of the MCS, to effectively reduce and prevent losses. In this paper, a resilience importance measure (RIM) for performance loss is proposed to evaluate the performance of the MCS. Specifically, a loss importance measure (LIM) is first proposed to indicate the component maintenance priority of the MCS under different failure conditions. Based on the LIM, RIMs for single component failure and multiple component failures were developed to measure the recovery efficiency of the system performance. Finally, a case study was conducted to demonstrate the proposed resilience measure for system reliability. Results provide a valuable reference for increasing the system security of the MCS and choosing the appropriate total maintenance cost.

Keywords: system reliability; system performance; resilience; maintenance; importance measure

1. Introduction

In the early days of nuclear reactors, nuclear power plants (NPPs) were mainly used for military purposes. As a result of the industry's continuous development and progress, NPPs began to be used primarily for nuclear power generation. However, following the widespread establishment and use of NPPs, nuclear accidents have highlighted the dangers of nuclear reactors. After the Chernobyl nuclear accident, people began to pay attention to nuclear safety and study the safety issues associated with nuclear reactors. In addition, issues such as waste and the economy also affect social and environmental acceptability [1]. For nuclear energy, promoting strengths and avoiding weaknesses has become a problem to be considered.

At present, the pressurized water reactor (PWR) is the most competitive reactor used in NPPs, and accounts for the largest proportion. The core system of the PWR is the main coolant system (MCS), also known as the primary loop system. It is composed of two to four identical cooling loops according to its capacity. Its main functions include transferring energy and cooling the core. In addition, because the water in the primary circuit is closed and the heat exchange is carried out through the heat transfer of the tube wall, the MCS can also prevent the leakage of radioactive materials. On 28 March 1979, a serious nuclear leakage occurred at the Three Mile Island nuclear power station in the United States, namely the Three Mile Island nuclear accident. At the time, the MCS was

Citation: Dui, H.; Xu, Z.; Chen, L.; Xing, L.; Liu, B. Data-Driven Maintenance Priority and Resilience Evaluation of Performance Loss in a Main Coolant System. *Mathematics* 2022, *10*, 563. https://doi.org/ 10.3390/math10040563

Academic Editor: János Sztrik

Received: 7 January 2022 Accepted: 8 February 2022 Published: 11 February 2022

 Publisher's
 Note:
 MDPI
 stays

 neutral with regard to jurisdictional
 claims in published maps and
 institutional affiliations.



Copyright: © 2022 by the authors. Licensee MDPI, Basel, Switzerland. This article is an open access article distributed under the terms and conditions of the Creative Commons Attribution (CC BY) license (https://creativecommons.org/license s/by/4.0/). not functioning due to human errors. This accident resulted in serious consequences, and the clean-up cost of reactor two alone reached USD 1 billion [2].

Due to the setting of redundant components, failure of some components may not cause the failure of the whole MCS, but some degradation in the system performance. In addition, failed components may have a negative effect on the components to which they are connected, possibly leading to cascading effects with more serious consequences. At this time, maintenance is essential for managing system reliability, preventing system failures, and improving the effectiveness of system operations [3]. Therefore, this paper considers the preventive maintenance of the remaining operational components while maintaining the failed components, to restore the system performance to a great extent. By combining resilience with importance measures, the recovery process of the MCS after an accident can be better guided. Specifically, in this paper, the resilience of the MCS is represented by the loss and recovery of system performance. The loss importance measure (LIM) is proposed to indicate the maintenance priority of the MCS components under different failure conditions. Considering the limited maintenance cost, we determined the preventive maintenance components set to maximize the system performance. Then, the resilience importance measures (RIMs) for single component failure and multiple component failures were used to evaluate the recovery efficiency of the MCS.

The rest of this paper is organized as follows. Section 2 presents some relevant works. Section 3 introduces the MCS of a nuclear reactor and presents the problem descriptions. Section 4 presents the component maintenance priority and proposes the resilience measure of the MCS. Section 5 uses a case study to illustrate the proposed method. Finally, Section 6 presents the conclusions.

2. Relevant Work

System resilience is the ability of a system to respond and recover quickly from an external disruptive event. In recent years, studies have been undertaken to analyze system resilience. Panteli and Mancarella [4] introduced a new sequential Monte-Carlo-based time-series simulation model to assess the resilience of power systems. Mao et al. [5] developed two metrics, including the resilience of cumulative performance loss and the resilience of restoration rapidity, to measure the resilience of the supply chain networks. Ali et al. [6] proposed an approach that considers the resilient behavior of collaborative Cyber-Physical systems to achieve the fail-operational goal in autonomous platooning systems. Zarei et al. [7] developed a fuzzy hybrid multi-criteria decision-making model for quantifying resilience. Hajializadeh and Imani [8] presented a new framework for building a resilience and vulnerability-informed decision support system. Kim et al. [9] established a resilience assessment model by quantifying the relationship between resilience and resilience components in the recovery from emergency accidents in NPPs. Combining the Markov model with dynamic Bayesian networks, Cai et al. [10] developed a novel evaluation methodology for resilience evaluation under the influence of various external disasters. Zeng et al. [11] developed a non-homogeneous semi-Markov reward process model for resilience analysis of multi-state systems.

The above research on system resilience shows that there is no unanimous measurement standard and method for the concept of system resilience. The study of the resilience of the MCS should focus on restoring the system to normal operation to the greatest extent as soon as possible, that is, determining how to quickly improve the efficiency recovery of the MCS, to avoid more serious consequences.

For the study of reactor reliability, Mullor et al. [12] described a general method for optimal reliability and imperfect maintenance activities of repairable equipment. The proposed procedure was illustrated using a real data example of an NPP. Rejc and Cepin [13] proposed an advanced method for common cause failure modeling and estimation, allowing more detailed reliability analyses. Ma et al. [14] investigated the reliability analysis and maintenance optimization approaches of two-unit warm standby cooling equipment. He et al. [15] used the methodology to assess the reliability of squib valves in

pressurized water NPPs. Hu and Peng [16] developed a dynamic reliability model with random and dependent transition probabilities for a non-repairable discrete-time multistate system. Mamdikar et al. [17] devised a reliability analysis framework validated with 32 safety-critical system instances of the NPP. Wakankar et al. [18] proposed an architecture model to quantitatively evaluate the reliability of the large reactor safety system. Tripathi et al. [19] used the dynamic flowgraph methodology to study the NPP and analyze its reliability. Most research regarding the reactor relates to its reliability evaluation and analysis, and the different costs of the MCS are not considered.

Importance measures can quantitatively describe the importance of each component of the system, which is valuable for design and failure analysis. In recent years, increasing research has been conducted on the importance theory [20–22]. For example, Xu et al. [23] proposed a new component importance measure for multi-state networks based on resilience from the perspective of the post-disaster recovery process. Chybowska et al. [24] developed methods for evaluating the importance of events during disasters. Fu et al. [25] proposed a new time-dependent importance measure for degrading components to address the component reassignment problem of degrading components. Fang et al. [26] used importance measure methods in the complex project risk management field and established priorities for further decision making. Kala [27] presented a new importance measure in a reliability-oriented global sensitivity analysis. Dui et al. [28] proposed a joint importance to identify components or component groups that can be used for preventive maintenance. Dui et al. [29] proposed a resilience importance measure to quantify the contribution of a component to the loss of system performance.

The main concerns of NPPs relate to their high cost, uncertainty, and severe aftermath of accidents. However, the above studies did not focus on these issues. In addition, when some components of the MCS fail, there is a lack of an appropriate importance measure to reflect the change in the maintenance priority of other components so as to guide the recovery process of the system. In order to prevent further escalation of the accident, determining how to quickly recover the system performance in the case of component failure has become a crucial issue to be considered. In the process of recovery, the quantitative expression of the resilience of the MCS is an open and challenging question.

In this paper, we address these questions by proposing a loss importance measure (LIM) that can indicate the maintenance priority of the MCS components under different failure conditions, in addition to resilience importance measures (RIMs) for single component failure and multiple component failures that can be used to evaluate the recovery efficiency of the MCS.

3. MCS and Problem Descriptions

This section analyzes the working principle and system structure of the reactor MCS, and describes the structure and function of the main components. The schematic diagram of the reactor coolant system is shown in Figure 1. The system consists of three similar loops. Each loop has a steam generator and a main pump connected with the reactor by the main pipe to form a closed cooling circuit. The nuclear fuel in the reactor releases much heat energy through the nuclear fission reaction. The coolant takes away the heat generated and cools the fuel assembly. Driven by the reactor coolant pump (PCR), the coolant flows into the steam generator through the pipe. The heat is transferred to the secondary circuit's main feedwater through the U-tube's wall heat transfer. The main feedwater is heated into steam and led into the main steam pipe, thus causing the steam turbine to generate power. A pressurizer is set in the first loop to compensate and adjust the volume and pressure of the system coolant. When the pressure is lower than a specific set value, the heater at the bottom of the pressurizer operates to heat the water in the pressurizer and generate steam, making the pressure rise. When the pressure is too high, the spray system is adjusted, and the coolant is introduced from the cold pipe of the system. The saturated steam in the pressurizer is condensed into water after being sprayed by the coolant to reduce the pressure value of the system. The pressure relief valve and safety valve are installed on the top of the pressurizer to protect the system from overpressure. When the system pressure exceeds a specific set value, the pressure relief valve and safety valve open, and part of the steam is sent to the pressure relief tank to reduce the system pressure. A safety injection pump and safety injection tank are set in each loop to form a safety injection system (RIS). When a loss of coolant accident (LOCA) occurs in the reactor coolant system (RCP) or the main steam system piping (VVP) breaks, the RIS can complete the core emergency cooling function so that the residual heat of the core can be discharged in time to ensure the integrity of the containment and limit the further development of the accident [30].



Figure 1. Schematic diagram of the MCS.

In this paper, the main components of MCS are analyzed and studied, and their influences on the system reliability are considered. It is assumed that the failure time of each component follows the Weibull distribution $W(t | \theta, \gamma)$, and components of the same type have the same parameters. The scale and shape parameters of each component are shown in Table 1. Table 2 lists the names and codes of the main components. During the system's working process, the steam generator and main coolant pump are in operation

most of the time. According to engineering experience, they are prone to failures during the system's service life, so they are most likely to be the vulnerable components.

No.	Component	θ	γ
1	Reactor pressure vessel	1860	2.43
2	Pressurizer	2730	3.92
3	Safety valve	3567	1.76
4	Steam generator	4235	2.14
5	Main coolant pump	6165	2.36
6	Safety injection pump	7304	3.46
7	Safety injection tank	3051	2.03

Table 1. Scale and shape parameters of each component.

Table 2. Major components of the MCS.

Code	Name	Code	Name
X1	Reactor pressure vessel	X10	Steam generator No.2
X2	Pressurizer	X11	Main coolant pump No.2
X3	Safety valve	X12	Safety injection pump No.4
X4	Safety injection pump No.1	X13	Safety injection tank No.2
X5	Steam generator No.1	X14	Safety injection pump No.5
X6	Main coolant pump No.1	X15	Steam generator No.3
X7	Safety injection pump No.2	X16	Main coolant pump No.3
X8	Safety injection tank No.1	X17	Safety injection pump No.6
X9	Safety injection pump No.3	X18	Safety injection tank No.3

In the MCS, there are three loops in the system. When a component in one of the loops fails, the other two loops are not affected by the faulty component. The whole system continues to run, but the system performance is degraded. When one component and its backups fail, the whole loop may fail. For example, when LOCA occurs and both X4 and X7 fail, the safety injection system cannot operate normally, and the whole first loop fails. The remainder of the components without backup are key components, and the failure of any key component can cause the whole system to crash. The specific problems to be solved in this paper are as follows.

- As a multi-state system, different states of components will lead to different performance levels of the MCS; how can the impact of the status change in other components on the system performance, when some components of the MCS fail, be evaluated?
- Under the constraints of maintenance resources, how can the combination of maintenance components to achieve the highest system performance, when one or more components of the MCS fail, be determined?
- In the current competitive energy market, the nuclear industry is committed to reducing maintenance costs while maintaining safe and reliable operations. Therefore, how can the maintenance efficiency of optimal preventive maintenance policies corresponding to different total maintenance costs at a certain time be measured so as to control maintenance costs and improve recovery efficiency?

4. Component Maintenance Priority and Resilience Measure for the MCS

The failure process of the system is the superposition of the failure processes of all components. Moreover, due to the comprehensive effects of each component state, the system presents different utilities. Therefore, we consider using system performance to quantitatively represent the loss of system performance caused by component failure. We use $a_0 \le a_1 \le ... \le a_M$ to represent the performance levels corresponding to the state space $\{0,1,2,...,M\}$ of the system. It is assumed that all the components of the MCS have two states: perfect function and failure (1 and 0). The state of component *i* is indicated by $X_i(t)$; a system state represents a combination of all system component states, the state of the MCS is indicated by S(X(t)), and X(t) is the state space of all MCS components. By default, $a_0=0$ when the MCS is at state 0 (complete failure). Thus, the performance of the system can be measured by the system utility expectation of different system states, which is expressed as:

$$U(X(t)) = \sum_{j=0}^{M} a_{j} \Pr[S(X(t)) = j]$$

= $\sum_{j=1}^{M} a_{j} \Pr[S(X(t)) = j] = \sum_{j=1}^{M} a_{j} \Pr[S(X_{1}(t), X_{2}(t), ..., X_{n}(t)) = j],$ (1)

where a_j is the performance level of the MCS when the system state is *j*. The states and corresponding performance level parameters of the MCS are shown in Appendix A.

4.1. LIM and Determining Component Maintenance Priority

We define the LIM in this section. LIM refers to the impact of other non-failed components on system performance when some components of MCS fail. The higher the LIM value of a component, the more the system performance will recover when the component is repaired, so the higher maintenance priority of the component. It can provide a theoretical basis for the determination of component maintenance priority.

1. When component *i* fails, the state of component *i* becomes 0, and the system performance can be expressed as:

$$U(0_i, X(t)) = \sum_{j=1}^{M} a_j \Pr[S(X_1(t), ..., X_{i-1}(t), 0_i, X_{i+1}(t), ..., X_n(t)) = j].$$
(2)

In this case, the LIM of component *k* is expressed in the form of a partial derivative. The LIM of component *k* is:

$$I_{k/i}(t) = \frac{\partial(U(0_i, X(t)))}{\partial \rho_k(t)} = \sum_{j=1}^{M} (a_j - a_{j-1}) [\Pr(S(1_k, 0_i, X(t)) \ge j) - \Pr(S(0_k, 0_i, X(t)) \ge j)],$$

(3)
$$\rho_k(t) = \Pr[X_k(t) = 1].$$

The proof of Equation (3) is shown in Appendix B.

2. Similarly, when multiple components fail, the system performance is:

$$U(0_{N'}, X(t)) = \sum_{j=1}^{M} a_j \Pr[S(0_{N'}, X(t)) = j],$$
(4)

where N' is the set of failed components.

At this point, the LIM of component *k* is equal to:

$$I_{k/N'}(t) = \frac{\partial (U(0_{N'}, X(t)))}{\partial \rho_k(t)} = \sum_{j=1}^{M} (a_j - a_{j-1}) [\Pr(S(1_k, 0_{N'}, X(t)) \ge j) - \Pr(S(0_k, 0_{N'}, X(t)) \ge j)]$$
(5)

When each component has the same maintenance cost, the preventive maintenance priority of the components can be determined by the ranking of their importance measures. However, in practice, the limited maintenance cost constraints should be considered, and each component's maintenance cost is often different (a component with a high importance measure may need a higher maintenance cost). Therefore, to maximize the expected system performance under cost constraints, the integer programming method can be used to determine the set of preventive maintenance components. When a single component *i* fails, the following integer programming problem needs to be solved:

$$Z = \max \sum_{\substack{k \in G, k \neq i}} I_{k/i}(t) \cdot x_k,$$

s.t. $c_i + \sum x_k \cdot c_k \le C,$
 $x_i \in \{0, 1\},$ (6)

where *G* is the set of system components, c_i is the maintenance cost of component *i*, c_k is the preventive maintenance cost of component *k*, and x_k is the decision variable indicating whether to repair component *k*. x_k is a 0–1 variable. *C* represents the total maintenance cost constraint.

When multiple components fail, the following integer programming problem needs to be solved:

$$Z = \max \sum_{k \in G, k \notin N'} I_{k/N'}(t) \cdot x_k,$$

s.t. $c_{N'} + \sum x_k \cdot c_k \le C,$
 $x_k \in \{0,1\},$ (7)

where $c_{N'}$ is the cost required to repair the failed components.

For the integer programming model above, the optimal solution is $\{x_k^*, k \neq i\}$ (for the single component failure case) and $\{x_k^*, k \notin N'\}$ (for the multi-component failures case). Thus, the optimal component maintenance priority set is $\{k \mid x_k^* = 1\}$.

4.2. RIM

After determining the preventive maintenance component set based on LIM, in order to measure the recovery efficiency of preventive maintenance when one or more components fail, this section proposes the RIM based on the system resilience.

Firstly, based on Equation (1), we can obtain:

м

$$\frac{dU(X(t))}{dt} = \frac{d(\sum_{j=1}^{m} a_j \operatorname{Pr}[S(X(t)) = j])}{dt} = \sum_{i=1}^{M} a_j \sum_{i=1}^{m} \frac{dR_i(t)}{dt} \frac{\partial \operatorname{Pr}[S(X(t)) = j]}{\partial R_i(t)}.$$
(8)

where $R_i(t)$ is the reliability of component *i*, $i \in [1, n]$, *n* is the number of system components.

Because

$$\Pr[S(X(t)) = j] = \Pr[X_i(t) = 1] \Pr[S(1_i, X(t)) = j] + \Pr[X_i(t) = 0] \Pr[S(0_i, X(t)) = j]$$

= $R_i(t) \Pr[S(1_i, X(t)) = j] + (1 - R_i(t)) \Pr[S(0_i, X(t)) = j]$

and $\lambda_i(t) = -\frac{dR_i(t) / dt}{R_i(t)}$, then we have:

$$\frac{dU(X(t))}{dt} = -\sum_{i=1}^{n} \sum_{j=1}^{M} a_j R_i(t) \lambda_i(t) \{ \Pr[S(1_i, X(t)) = j] - \Pr[S(0_i, X(t)) = j] \} = -\sum_{i=1}^{n} I_i(t) \{ \Pr[S(1_i, X(t)] \} = -\sum_{i=1}$$

where $I_i(t)$ is the Integrated importance measure of component *i*. The loss of system performance per unit time when components fail is expressed as a performance loss importance measure (PLIM). The improvement of system performance per unit time in the case of component maintenance is expressed as a performance recovery importance measure (PRIM). Then the RIM of the maintenance component set is discussed in two cases.

1. Single component failure

The loss of system performance per unit time is equal to the loss of system performance caused by the failure of component *i*. Based on Equation (9), PLIM of component u is obtained as follows:

$$PLIM_{u}(t) = \left| \frac{d(U(X(t)) - U(0_{u}, X(t)))}{dt} \right| = \left| \frac{dU(X(t))}{dt} - \frac{dU(0_{u}, X(t))}{dt} \right|$$

$$= \left| -\sum_{i=1}^{n} I_{i}(t) + \sum_{i=1}^{n} I_{i}(t)_{0_{u}} \right| = I_{u}(t)$$
 (10)

where $I_u(t)$ is the Integrated importance measure of component *u*.

In the process of repairing the failed component u and preventively maintaining component set $\{k \mid x_k^* = 1, k \neq u\}$, the improvement of system performance per unit time is equal to the sum of PRIM of all non-failed components in the system:

$$PRIM_{k/u}(t) = I_{k/u}(t)^{*}_{\{k|x_{k}^{*}=1, k\neq u\}} - I_{k/u}(t)_{\{k|x_{k}^{*}=1, k\neq u\}},$$
(11)

where $PRIM_{k/u}(t)$ is the contribution of the set of preventively maintained components to system performance improvement while repairing component *u*. $I_{k/u}(t)^*$ represents system performance after the preventive maintenance, $I_{k/u}(t)$ represents system performance before the preventive maintenance.

Based on Equations (10) and (11), we can define and evaluate the RIM of component *k* as:

$$RIM_{k/u}(t) = \frac{PRIM_{k/u}(t)}{PLIM_{u}(t)}$$
(12)

That, is, the RIM of component *k* is equal to the ratio of the sum of PRIM values of all preventively maintained components to PLIM. The larger RIM of components, the higher the recovery efficiency of system performance when they are repaired, which means that higher maintenance priority should be provided for these components for the best return in improving the system performance.

2. Multiple components failures

The failed components are represented as the set $N' = \{i_1, i_2, i_3...i_y\}$. The loss of system performance per unit time is equal to the loss of performance caused by the failure of components $i_1, i_2, i_3...i_y$ to state 0. The PLIM for the set is:

$$PLIM_{N'}(t) = \left| \frac{d(U(X(t)) - U(0_{N'}, X(t)))}{dt} \right| = \left| \frac{dU(X(t))}{dt} - \frac{dU(0_{N'}, X(t))}{dt} \right|$$

$$= \left| -\sum_{i=1}^{n} I_{i}(t) + \sum_{i=1}^{n} I_{i}(t)_{0_{N'}} \right| = \sum_{i=1}^{y} I_{i}(t).$$
 (13)

Based on Equation (11), the PRIM for multi-component failure is:

$$PRIM_{k/N'}(t) = I_{k/N'}(t)^{*}_{\{k|x_{k}^{*}=1, k \notin N'\}} - I_{k/N'}(t)_{\{k|x_{k}^{*}=1, k \notin N'\}}$$
(14)

Based on Equations (13) and (14), the RIM for the failed component *k* is defined and evaluated as:

$$RIM_{k/N'}(t) = \frac{PRIM_{k/N'}(t)}{PLIM_{N'}(t)}$$
(15)

In addition, an illustration using the parallel-serial structure of the MCS is shown in Appendix C to indicate the specific calculation process of the above formula.

5. Case Study

This section takes the MCS in Figure 1 to illustrate the proposed method in Section 4. The component maintenance priority based on the LIM under different illustrative failure conditions is shown in Figures 2 and 3.



Figure 2. Component maintenance priority in the case of a single component failure.



Figure 3. Component maintenance priority in the case of multiple component failures.

The maintenance priority of each component under different conditions can be shown by the LIM values of the MCS components. It can be seen from Figures 2 and 3 that LIM values decrease rapidly before 1000 h and then decrease slowly to 0. It can also be observed that the maintenance priority of the reactor pressure vessel, pressurizer, and safety valve are always high because they are the key components of the MCS, and the failure of these components may lead to the failure of the whole system. Therefore, we should focus on the maintenance of these components. Safety injection pumps and safety injection tanks always have the lowest maintenance priority; thus, they have a lower chance of receiving preventive maintenance. Therefore, the high reliability of these two components should be strictly maintained to ensure the normal operation of the reactor.

When the MCS starts to operate, the maintenance priority of the safety valve is higher than that of the reactor pressure vessel, but the slope of the safety valve curve is larger. The maintenance priorities of the two components change as time proceeds. Therefore, the maintenance focus needs to be adjusted over time. In addition, comparing the curves under different conditions, it can be seen that the impact of the backup components corresponding to the failed components on the system performance will become greater, so the preventive maintenance priority of the backup components will also become higher. Therefore, when a component fails, more attention should be paid to its redundant components in other loops to ensure their normal operation.

After determining the maintenance priority of each component under different conditions, considering the cost constraints, different total maintenance costs will have corresponding different preventive maintenance policies. The maintenance and preventive maintenance costs of each component are shown in Table 3.

Components	No.	Repair Cost	PM Cost
Reactor pressure vessel	X1	12,000	5700
Pressurizer	X2	7000	3400
Safety valve	X3	5000	2300
Safety injection pump	X4, X7, X9, X12, X14, X17	4000	1800
Steam generator	X5, X10, X15	9000	4200
Main coolant pump	X6, X11, X16	10,000	4700
Safety injection tank	X8, X13, X18	3000	1500

Table 3. Maintenance cost and preventive maintenance cost of each component.

Solving the optimization problems of Equations (6) and (7), the optimal preventive maintenance component set at a specific time under different cost constraints can be obtained. Four cases are selected to analyze the impact of different maintenance cost constraints on the selection of preventive maintenance components. The results are shown in Tables 4–7, where 1 means the component is selected for preventive maintenance, and 0 means the component is not selected for maintenance. Considering the maintenance cost and maintenance priority, it can be seen that, due to the lower preventive maintenance cost and higher maintenance priority, the safety valve has priority among the preventive maintenance components in different situations. Considering the influence of time, at 600 h, the choice of the reactor pressure vessel or safety valve for preventive maintenance is preferred due to the large gap between the maintenance priority curves of key components and other components. At 1000 h, the gap between the repair priority curves of each component becomes smaller, and the low maintenance costs of the safety injection pump and safety injection tank make them the preferred choice for preventive maintenance. In addition, the failure of different components will also result in the selection of their preferred components for preventive maintenance. When X10 fails, the pressurizer is more likely to be selected for preventive maintenance due to the increase in total maintenance cost. When X11 fails, the reactor pressure vessel is more likely to be selected. In the case of X9 and X10 failures, preventive maintenance for safety injection pump is preferred. When X10, X11, and X13 fail, preventive maintenance for safety injection tank is preferred.

Table 4. X10 failure, t = 600)h.
--------------------------------------	-----

Cost Constraint Part	15,000	16,000	17,000	18,000	19,000	20,000	21,000	22,000
Reactor pressure vessel	0	0	1	1	0	0	1	1
Pressurizer	1	0	0	0	1	1	1	1
Safety valve	1	1	1	1	1	1	1	1
Steam generator	0	1	0	0	1	1	0	0
Main coolant pump	0	0	0	0	0	0	0	0
Safety injection pump	0	0	0	0	0	0	0	0
Safety injection tank	0	0	0	0	0	0	0	1

Cost Constraint								
	15,000	16,000	17,000	18,000	19,000	20,000	21,000	22,000
Part								
Reactor pressure vessel	0	0	0	1	1	1	0	1
Pressurizer	0	1	0	0	0	0	1	1
Safety valve	1	1	1	1	1	1	1	1
Steam generator	0	0	0	0	0	0	0	0
Main coolant pump	0	0	1	0	0	0	1	0
Safety injection pump	1	0	0	0	0	1	0	0
Safety injection tank	0	0	0	0	0	0	0	0

Table 5. X11 failure, t = 600h.

Table 6. X10 and X9 failures, t = 1000h.

Cost Constraint								
	18,000	19,000	20,000	21,000	22,000	23,000	24,000	25,000
Part								
Reactor pressure vessel	0	0	0	0	0	1	1	0
Pressurizer	0	0	0	1	0	0	0	1
Safety valve	1	1	1	1	1	1	1	1
Steam generator	0	0	1	0	1	0	0	1
Main coolant pump	0	0	0	0	0	0	0	0
Safety injection pump	1	1	0	1	1	1	1	1
Safety injection tank	0	1	0	0	0	0	0	0

Table 7. X10, X11, X13 failures, t = 1000h.

Cost Constraint								
	27,000	28,000	29,000	30,000	31,000	32,000	33,000	34,000
Part								
Reactor pressure vessel	0	0	0	0	0	1	1	0
Pressurizer	0	0	0	0	0	0	0	1
Safety valve	1	1	1	1	1	1	1	1
Steam generator	0	0	0	1	1	0	0	1
Main coolant pump	0	0	0	0	0	0	0	0
Safety injection pump	0	1	1	0	0	0	0	0
Safety injection tank	1	1	1	1	1	1	1	1

Finally, the RIM values corresponding to the optimal preventive maintenance policies with different total maintenance costs are calculated when some components fail at a specific time. The results are shown in Figure 4. With the increase in the total maintenance cost, the number of components selected for preventive maintenance increases, and then the RIM value increases continuously in the form of a ladder. When X10 fails at 600 h, the RIM value does not increase significantly in the early stage but increases rapidly when the total maintenance cost is 19,000, and the subsequent increase is no longer obvious. In view of this situation, the total maintenance cost of 19,000 is the best, and can result in high recovery efficiency and control the total maintenance cost. When X11 fails, and the total maintenance cost is 16,000 and 21,500, the RIM value increases rapidly at 600 h. The appropriate maintenance cost should be selected according to the actual cost and performance requirements. When multiple components fail, the set of components corresponding to different maintenance costs changes less, so the change in the RIM value is less than that of a single component. The total maintenance cost also needs to be controlled according to the actual situation.



Figure 4. RIM when total maintenance cost changes.

6. Conclusions

This paper proposes a novel LIM measure to evaluate the effect of the failure of one or multiple components on the system performance in the case of different failure conditions. The evaluation of the LIM can facilitate the determination of the maintenance priority of the MCS components. Based on the LIM, the optimal preventive maintenance component set under a cost constraint is calculated. Then, we propose the RIM of preventive maintenance to quantitatively evaluate the loss of system performance caused by component failure and the recovery of system performance after preventive maintenance of components so as to calculate the recovery efficiency.

For the case study conducted on the MCS, based on the LIM evaluation, it is verified that the key components of the MCS are the reactor pressure vessel, pressurizer, and safety valve. The case study also demonstrates that a component failure can lead to higher maintenance priority of its redundant components in other loops. The simulation results for the RIM show that, with the increase in the total maintenance cost, the RIM value increases continuously in the form of a ladder, and the RIM value increases significantly at some specific maintenance cost values. The results can provide valuable information to guide the recovery process.

In future research, we will consider extending and applying the proposed method to other technological or engineering multi-state systems. By defining the system performance and analyzing the impact of components on the system performance, the maintenance priority of components can be determined based on this to formulate the corresponding maintenance strategy to improve system resilience. We are also interested in extending the proposed LIM and RIM for risk analysis of safety-critical systems, including MCSs.

Author Contributions: Conceptualization, H.D. and L.C.; methodology, H.D.; software, Z.X.; validation, L.C., L.X. and B.L.; formal analysis, L.C.; investigation, H.D. and L.C.; resources, L.X.; data curation, B.L.; writing—original draft preparation, H.D. and Z.X.; writing—review and editing, L.X. and B.L.; supervision, H.D. and L.C.; funding acquisition, H.D. All authors have read and agreed to the published version of the manuscript.

Funding: This research was funded by the Ministry of Education's Humanities and Social Sciences Planning Fund (No. 20YJA630012), the Key Science and Technology Program of Henan Province (No. 222102520019), the Program for Science & Technology Innovation Talents in Universities of Henan Province (No. 22HASTIT022), the Program for young backbone teachers in Universities of Henan Province (No. 2021GGJS007), and the National Natural Science Foundation of China (No. U1904211).

Institutional Review Board Statement: Not applicable.

Informed Consent Statement: Not applicable.

Data Availability Statement: The authors confirm that the data supporting the findings of this study are available within the article.

Conflicts of Interest: The authors declare no conflict of interest.

Appendix A

According to Table A1, the MCS has 48 states, namely intermediate states 1–46, complete failure state 47, and perfect state 48. Each state represents the failure of the corresponding components. For example, in system state 40, 'X11 X12 X13' means that components X11, X12, and X13 are in the failure state, whereas other components are the in working state. When all components in the system stop working, the system is in complete failure state, $a_i = 0$. When all components are working, $a_i = 1$.

Table A1. System states and corresponding performance level parameters.

j	Systen	n States	a_j	j		System	n States		a_j
1	Х9		0.9	25	X11	X9			0.54
2	X12		0.9	26	X11	X12			0.54
3	X14		0.9	27	X16	X14			0.54
4	X17		0.9	28	X16	X17			0.54
5	X10		0.8	29	X10	X11	X13		0.432
6	X15		0.8	30	X15	X16	X18		0.432
7	X11		0.6	31	X10	X11	X9		0.432
8	X16		0.6	32	X10	X11	X12		0.432
9	X13		0.9	33	X15	X16	X14		0.432
10	X18		0.9	34	X15	X16	X17		0.432
11	X9	X14	0.81	35	X10	X9	X13		0.648
12	X9	X17	0.81	36	X10	X12	X13		0.648
13	X12	X14	0.81	37	X15	X14	X18		0.648
14	X12	X17	0.81	38	X15	X17	X18		0.648
15	X10	X9	0.72	39	X11	X9	X13		0.486
16	X10	X12	0.72	40	X11	X12	X13		0.486
17	X15	X14	0.72	41	X16	X14	X18		0.486
18	X15	X17	0.72	42	X16	X17	X18		0.486
19	X10	X13	0.72	43	X10	X11	X9	X13	0.3888
20	X15	X18	0.72	44	X10	X11	X12	X13	0.3888
21	X11	X13	0.54	45	X15	X16	X14	X18	0.3888

22	X16	X18	0.54	46	X15	X16	X17	X18	0.3888	
23	X10	X11	0.48	47		failure				
24	X15	X16	0.48	48	perfect function				1	

Appendix B

Proof of Equation (3):

We have:

$$U(X(t)) = \sum_{j=1}^{M} (a_j - a_{j-1}) \Pr[S(0_i, X(t)) \ge j] + I_i^G(t) \cdot \rho_{i1}(t),$$

$$\rho_{i1}(t) = \Pr[X_i(t) = 1],$$
(A1)

where $I^{G}(i)$ is the Griffith importance of component *i*. When component *i* fails, system performance equals:

$$U(0_i, X(t)) = \sum_{j=1}^{M} a_j \Pr[S(X_1(t), \dots, X_{i-1}(t), 0_i, X_{i+1}(t), \dots, X_n(t)) = j]$$
(A2)

At this time, the influence of component *k* on system performance can be expressed as:

$$I_{k/i}(t) = \frac{\partial (U(0_i, X(t)))}{\partial \rho_{k1}(t)} = \frac{\partial I_i^o(t) \cdot \rho_{i1}(t)}{\partial \rho_{k1}(t)}$$

$$= \sum_{j=1}^{M} (a_j - a_{j-1}) [\Pr(S(1_k, 0_i, X(t)) \ge j) - \Pr(S(0_k, 0_i, X(t)) \ge j)],$$
(A3)

where $\rho_{k1}(t) = \Pr[X_k(t) = 1].$

Appendix C

Illustration using the parallel-series structure of the MCS:

Figure A1 is the high-level abstraction of the MCS, which appears as a parallel-series structure. In order to facilitate the calculation, the components are recoded. We assume that all components X_{ij} have two states: perfect function and failure. The reliability of component X_{ij} is $R_{ij}(t)$, the failed component is X_{ab} . Based on Equation (3), the LIM of component X_{uu} can be expressed as:

$$I_{mn/ab}(t) = \frac{\partial (U(0_{ab}, X(t)))}{\partial \rho_{mn}} = \sum_{z=1}^{M} s_z [\Pr(S(1_{mn}, 0_{ab}, X(t)) = z) - \Pr(S(0_{mn}, 0_{ab}, X(t)) = z)]$$
(A4)

where *z* represents the state of the MCS, s_z is the performance level corresponding to the system state.



Figure A1. High-level parallel-series structure of the MCS.

1. When the failed components at state Z_1 are inseries with X_{ab} and a=1, we have:

$$\begin{aligned} &\Pr(S(1_{2n}, 0_{1b}, X(t)) = z_1)) = 1 - [(1 - \prod_{j \neq n} R_{2j}(t))(1 - R_{31}(t)R_{32}(t)R_{33}(t)R_{34}(t)R_{35}(t))] = 1 - [(1 - \prod_{j \neq n} R_{2j}(t))(1 - \prod_{j=1}^{5} R_{3j}(t))], \\ &\Pr(S(0_{2n}, 0_{1b}, X(t)) = z_1))_{m \neq a} = R_{31}(t)R_{32}(t)R_{33}(t)R_{34}(t)R_{35}(t) = \prod_{j=1}^{5} R_{3j}(t), \\ &\Pr(S(1_{3n}, 0_{1b}, X(t)) = z_1)) = 1 - [(1 - \prod_{j \neq n} R_{3j}(t))(1 - R_{21}(t)R_{22}(t)R_{23}(t)R_{24}(t)R_{25}(t))] = 1 - [(1 - \prod_{j \neq n} R_{3j}(t))(1 - \prod_{j=1}^{5} R_{2j}(t))], \\ &\Pr(S(0_{3n}, 0_{1b}, X(t)) = z_1)) = R_{21}(t)R_{22}(t)R_{23}(t)R_{24}(t)R_{25}(t) = \prod_{j=1}^{5} R_{2j}(t), \end{aligned}$$

thus,

$$[\Pr(S(1_{2n}, 0_{1b}, X(t)) = z_1) - \Pr(S(0_{2n}, 0_{1b}, X(t)) = z_1)]$$

= 1-[(1- $\prod_{j \neq n} R_{2j}(t)$)(1- $\prod_{j=1}^{5} R_{3j}(t)$) - $\prod_{j=1}^{5} R_{3j}(t)$
= ($\prod_{j \neq n} R_{2j}(t)$)(1- $\prod_{j=1}^{5} R_{3j}(t)$), (A5)

5

$$[\Pr(S(1_{3n}, 0_{1b}, X(t)) = z_1) - \Pr(S(0_{3n}, 0_{1b}, X(t)) = z_1)]$$

= 1-[(1- $\prod_{j \neq n} R_{3j}(t)$)(1- $\prod_{j=1}^5 R_{2j}(t)$)- $\prod_{j=1}^5 R_{2j}(t)$
= ($\prod_{j \neq n} R_{3j}(t)$)(1- $\prod_{j=1}^5 R_{2j}(t)$). (A6)

When a=2,

$$\begin{aligned} &\Pr(S(1_{1n}, 0_{2b}, X(t)) = z_1)) = 1 - [(1 - \prod_{j \neq n} R_{1j})(1 - R_{31}(t)R_{32}(t)R_{33}(t)R_{34}(t)R_{35}(t))] = 1 - [(1 - \prod_{j \neq n} R_{1j}(t))(1 - \prod_{j=1}^5 R_{3j}(t))], \\ &\Pr(S(0_{1n}, 0_{2b}, X(t)) = z_1)) = R_{31}(t)R_{32}(t)R_{33}(t)R_{34}(t)R_{35}(t) = \prod_{j=1}^5 R_{3j}(t), \\ &\Pr(S(1_{3n}, 0_{2b}, X(t)) = z_1)) = 1 - [(1 - \prod_{j \neq n} R_{3j})(1 - R_{11}(t)R_{12}(t)R_{13}(t)R_{14}(t)R_{15}(t)R_{16}(t))] = 1 - [(1 - \prod_{j \neq n} R_{3j}(t))(1 - \prod_{j=1}^6 R_{1j}(t))], \\ &\Pr(S(0_{3n}, 0_{2b}, X(t)) = z_1)) = R_{11}(t)R_{12}(t)R_{13}(t)R_{14}(t)R_{15}(t)R_{16}(t) = \prod_{j=1}^6 R_{1j}(t), \end{aligned}$$

so,

$$[\Pr(S(1_{1n}, 0_{2b}, X(t)) = z_1) - \Pr(S(0_{1n}, 0_{2b}, X(t)) = z_1)]$$

$$= 1 - [(1 - \prod_{j \neq n} R_{1j}(t))(1 - \prod_{j=1}^5 R_{3j}(t)) - \prod_{j=1}^5 R_{3j}(t)$$

$$= (\prod_{j \neq n} R_{1j}(t))(1 - \prod_{j=1}^5 R_{3j}(t)),$$

$$[\Pr(S(1_{3n}, 0_{2b}, X(t)) = z_1) - \Pr(S(0_{3n}, 0_{2b}, X(t)) = z_1)]$$

$$= 1 - [(1 - \prod_{j \neq n} R_{3j}(t))(1 - \prod_{j=1}^6 R_{1j}(t)) - \prod_{j=1}^6 R_{1j}(t)$$

$$= (\prod_{j \neq n} R_{3j}(t))(1 - \prod_{j=1}^6 R_{1j}(t)).$$
(A7)

By combining Equations (A5)–(A8), we obtain:

$$[\Pr(S(1_{mn}, 0_{ab}, X(t)) = z_1) - \Pr(S(0_{mn}, 0_{ab}, X(t)) = z_1)] = (\prod_{j \neq n} R_{mj}(t))(1 - \prod R_{ij}(t)), i \neq m, i \neq a$$
(A9)

Similarly, it can be concluded that:

$$[\Pr(S(1_{ab}, X(t) = z_1))] - [\Pr(S(0_{ab}, X(t) = z_1))] = 0$$
(A10)

2. When the failure components at state Z_2 are in parallel with X_{ab} and a=1,

$$\begin{split} &\Pr(S(1_{2n}, 0_{1b}, X(t)) = z_1)) = \prod_{j \neq n} R_{2j}(t), \ \Pr(S(0_{2n}, 0_{1b}, X(t)) = z_1)) = 0, \\ &\Pr(S(1_{3n}, 0_{1b}, X(t)) = z_1)) = \prod_{j \neq n} R_{3j}(t), \ \Pr(S(0_{3n}, 0_{1b}, X(t)) = z_1)) = 0, \end{split}$$

so,

$$\Pr(S(1_{2n}, 0_{1b}, X(t)) = z_1)) - \Pr(S(0_{2n}, 0_{1b}, X(t)) = z_1)) = \prod_{j \neq n} R_{2j}(t)$$

$$\Pr(S(1_{3n}, 0_{1b}, X(t)) = z_1)) - \Pr(S(0_{3n}, 0_{1b}, X(t)) = z_1)) = \prod_{j \neq n} R_{3j}(t).$$

When a=2 or a=3, after calculation, we can obtain:

$$[\Pr(S(1_{mn}, 0_{ab}, X(t)) = z_2) - \Pr(S(0_{mn}, 0_{ab}, X(t)) = z_2)] = \prod_{j \neq n} R_{mj}(t)$$
(A11)

Similarly, it can be concluded that:

$$[\Pr(S(1_{ab}, X(t) = z_2)] - [\Pr(S(0_{ab}, X(t) = z_2)] = (\prod_{j \neq b} R_{aj}(t))(1 - \prod R_{ij}(t)),$$

 $i \neq a, X_{ii} \notin \{ \text{ failure components in state } Z_2 \}.$
(A16)

Based on Equations (A9) and (A11), the LIM of X_{mn} can be obtained as:

$$I_{mn/ab}(t) = \sum_{z_1} s_{z_1} [(\prod_{j \neq n} R_{mj}(t))(1 - \prod R_{ij}(t)), i \neq m, i \neq a] + \sum_{z_2} s_{z_2} \prod_{j \neq n} R_{mj}(t)$$
(A17)

Then, based on Equations (A10) and (A16), the PLIM for component X_{ab} can be expressed as:

$$PLIM_{ab}(t) = I_{ab}^{IIM}(t) = \sum_{z} a_{z}R_{ab}(t)\lambda_{ab}(t) \{ [\Pr(S(1_{ab}, X(t) = z)] - [\Pr(S(0_{ab}, X(t) = z)] \}$$

= [\Pr(S(1_{ab}, X(t) = z_{2})] - [\Pr(S(0_{ab}, X(t) = z_{2})] = (\prod_{j \neq b} R_{aj}(t))(1 - \prod R_{ij}(t)), \qquad (A18)
 $i \neq a, X_{ij} \notin \{ failure \ components \ in \ state \ Z_{2} \}.$

We use *A*' to represent the set of failed components. The time before maintenance is represented by t_1 , and t_2 means the time after maintenance. Based on Equations (12) and (A18), the PRIM is:

$$PRIM_{ab}(t) = R_{ij}(t_2)\lambda_{ij}(t_2)\sum_{X_{ij}\in A'} I_{ij/ab}(t_2) - R_{ij}(t_1)\lambda_{ij}(t_1)\sum_{X_{ij}\in A'} I_{ij/ab}(t_1)$$
(A19)

Based on Equation (12), the RIM for X_{ab} is obtained as:

$$RIM_{A'/ab}(t) = \frac{PRIM_{A'/ab}(t)}{PLIM_{ab}(t)}$$
(A16)

References

- Ashley, S.F.; Fenner, R.A.; Nuttall, W.J.; Parks, G.T. Life-cycle impacts from novel thorium-uranium-fuelled nuclear energy systems. *Energy Convers. Manag.* 2015, 101, 136–150.
- 2. Bot, P. Human reliability data, human error and accident models—Illustration through the Three Mile Island accident analysis. *Reliab. Eng. Syst. Saf.* **2004**, *83*, 153–167.
- 3. Li, Y.F.; Xu, J.; Liang, Z.L.; Wang, K.B. Generalized condition-based maintenance optimization for multi-component systems considering stochastic dependency and imperfect maintenance. *Reliab. Eng. Syst. Saf.* **2021**, *211*, 107592.
- 4. Panteli, M.; Mancarella, P. Modeling and Evaluating the Resilience of Critical Electrical Power Infrastructure to Extreme Weather Events. *IEEE Syst. J.* 2017, *11*, 1733–1742.
- Mao, X.; Lou, X.; Yuan, C.; Zhou, J. Resilience-Based Restoration Model for Supply Chain Networks. *Mathematics* 2020, *8*, 163. https://doi.org/10.3390/math8020160033.
- Ali, N.; Hussain, M.; Hong, J.E. Fault-Tolerance by Resilient State Transition for Collaborative Cyber-Physical Systems. *Mathematics* 2021, 9, 2851. https://doi.org/10.3390/math9222851.
- Zarei, E.; Ramavandi, B.; Darabi, A.H.; Omidvar, M. A framework for resilience assessment in process systems using a fuzzy hybrid MCDM model. J. Loss Prev. Process Ind. 2021, 69, 104375.
- Hajializadeh, D.; Imani, M. RV-DSS: Towards a resilience and vulnerability- informed decision support system framework for interdependent infrastructure systems. *Comput. Ind. Eng.* 2021, 156, 107276.
- Kim, J.T.; Kim, J.; Seong, P.H.; Park, J. Quantitative resilience evaluation on recovery from emergency situations in nuclear power plants. *Ann. Nucl. Energy* 2021, 156, 108220.
- 10. Cai, B.; Zhang, Y.; Wang, H.; Liu, Y.; Ji, R.; Gao, C.; Kong, X.; Liu, J. Resilience evaluation methodology of engineering systems with dynamic-Bayesian-network-based degradation and maintenance. *Reliab. Eng. Syst. Saf.* **2021**, 209, 107464.
- 11. Zeng, Z.G.; Du, S.J.; Ding, Y. Resilience analysis of multi-state systems with time-dependent behaviors. *Appl. Math. Model.* **2021**, *90*, 889–911.
- Mullor, R.; Mulero, J.; Trottini, M. A modelling approach to optimal imperfect maintenance of repairable equipment with multiple failure modes. *Comput. Ind. Eng.* 2019, 128, 24–31.
- 13. Rejc, Z.B.; Cepin, M. An extension of Multiple Greek Letter method for common cause failures modelling. J. Loss Prev. Process Ind. 2014, 29,144-54.
- 14. Ma, X.Y.; Liu, B.; Yang, L.; Peng, R.; Zhang, X.D. Reliability analysis and condition-based maintenance optimization for a warm

standby cooling system. Reliab. Eng. Syst. Saf. 2020, 193, 106588.

- 15. He, J.; Bao, T.; Wu, J.; Shao, G.; Du, D.; Le, X.; Zhang, Q. Reliability assessment and data processing techniques of the squib valve in pressurized water NPPs. *Nucl. Eng. Des.* **2018**, 332, 59–69.
- 16. Hu, L.M.; Peng, R. Reliability modeling for a discrete time multi-state system with random and dependent transition probabilities. *Proc. Inst. Mech. Eng. Part O J. Risk Reliab.* 2019, 233, 747–760.
- 17. Mamdikar, M.R.; Kumar, V.; Singh, P.; Singh, L. Reliability and performance analysis of safety-critical system using transformation of UML into state space models. *Ann. Nucl. Energy* **2020**, *146*, 107628.
- Wakankar, A.; Kabra, A.; Bhattacharjee, A.K.; Karmakar, G. Architectural model driven dependability analysis of computerbased safety system in nuclear power plant. *Nucl. Eng. Technol.* 2019, *51*, 463–478.
- 19. Tripathi, M.; Singh, L.K.; Singh, S. Dynamic reliability framework for a Nuclear Power Plant using dynamic flowgraph methodology. *Ann. Nucl. Energy* 2020, *143*, 107467.
- 20. Levitin, G.; Ben-Haim, H. Importance of protections against intentional attacks. Reliab. Eng. Syst. Saf. 2008, 93, 639-646.
- 21. Dui, H.; Li, S.; Xing, L.; Liu, H. System performance-based joint importance analysis guided maintenance for repairable systems. *Reliab. Eng. Syst. Saf.* **2019**, *186*, 162–175.
- 22. Levitin, G.; Podofillini, L.; Zio E. Generalised importance measures for multi-state elements based on performance level restrictions. *Reliab. Eng. Syst. Saf.* 2003, *82*, 287–298.
- Xu, Z.P.; Ramirez-Marquez, J.E.; Liu, Y.; Xiahou, T.F. A new resilience-based component importance measure for multi-state networks. *Reliab. Eng. Syst. Saf.* 2020, 193, 106591.
- Chybowska, D.; Chybowski, L.; Guze, S.; Wilczynski, P. A method for determining critical events during large disasters of production platforms. J. Loss Prev. Process Ind. 2021, 72, 104528.
- Fu, Y.Q.; Yuan, T.; Zhu, X.Y. Importance-measure based methods for component reassignment problem of degrading components. *Reliab. Eng. Syst. Saf.* 2019, 190, 106501.
- 26. Fang, C.; Marle, F.; Xie, M. Applying importance measures to risk analysis in engineering project using a risk network model. *IEEE Syst. J.* **2017**, *11*, 1548–1556.
- 27. Kala, Z. New Importance Measures Based on Failure Probability in Global Sensitivity Analysis of Reliability. *Mathematics* **2021**, *9*, 2425. https://doi.org/10.3390/math9192425.
- Dui, H.; Tian, T.; Zhao, J.; Wu, S. Comparing with the joint importance under consideration of consecutive-k-out-of-n system structure changes. *Reliab. Eng. Syst. Saf.* 2022, 219, 108255.
- 29. Dui, H.; Zheng, X.; Wu, S. Resilience analysis of maritime transportation systems based on importance measures. *Reliab. Eng. Syst. Saf.* **2021**, *209*, 107461.
- Yang, Z.D.; Zhou, L.Y.; Zhou, J.; Luan, X.C.; Wang, J.L. Simulation research on passive safety injection system of marine nuclear power plant based on compressed gas. *Ann. Nucl. Energy* 2020, 145, 107552.